



■ CERTIFICATE



Hygienic Qualification of Air purification device, PAC 1080 based on VDI 6022-1:2018-01

CONTRACTEE	Miele & Cie. KG
INSPECTED OBJECT	Air purification device model PAC 1080
INSPECTED SCOPE	Evaluation of the hygienic safety and usability in medically used rooms without particular hygienic requirements (e.g. room class II) and conformity based on VDI 6022-1: 2018-01.
INSPECTION REPORT	11292-GUT-LR-0121-A
INSPECTION RESULT	The hygienic harmlessness and conformity of the air purification device PAC 1080 (with a HEPA filter of class H-14 according to DIN EN 1822-1:2019-10) based on VDI 6022-1:2018-01 is confirmed. A particulate and microbiological reduction in the room air has been demonstrated through the use of the air cleaning device.
DATE OF ISSUE	2021-01-18
AUTHORISATION	Dr. Frank Wille, Münster



Dr. Frank Wille